

NORTH ATTLEBOROUGH WATER DIVISION								
2022 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources								
Sample Collection Date	Water Treatment Plant	Whiting Treatment- with Highway Well - 10032	Whiting Treatment- No Highway Well- 10031	McKeon Treatment	Hillman Well	KIOSK - Vending Unit	Adamsdale Well (offline since December 2, 2020)	MCL (ng/L)
	EPTDS	Whiting Street	Whiting Street	Mary Kennedy Dr.	Huntsbridge Road	Whiting Street	Grandview Drive	
1/20/2022	January	12.3	17.4	OFFLINE	16.8	not detected	No Longer Sampled	20
2/16/2022	February	11.8	12.1	33.2	13.6	not detected		
3/09/2022	March	14.8	16.5	16.4	13.5	not detected		
	Quarter 1 Averages	12.9	15.3	24.8	14.6	0		
4/04/2022	April	14.1	17.0	15.4	13.8	not detected		20
5/09/2022	May	15.0	19.2	18.8	Next sample collection July 2022	not detected		
6/09/2022	June	14.9	18.2	21.0		not detected		
	Quarter 2 Averages	18.1	18.4	13.8	0			
7/11/2022	July	18.8	17.3	28.6	18.3	not detected		20
	Quarter 3 Averages							
							20	
	Quarter 4 Averages							
							-	

KEY:

EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system) ng/L = nanograms per liter, also equal to parts per trillion (ppt)

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

NOTES:

Yellow highlight = Violation

Red highlight=Offline from system

Violation/compliance with regulation based on locational Quarterly Averages Adamsdale Well is currently an inactive source