

TOWN OF NORTH ATTLEBORO WATER DIVISION

IRRIGATION METER REQUIREMENTS

DEDUCT METERS ARE NOT ALLOWED.

METER MUST BE PLUMBED IN BEFORE EXISTING METER (SEE EXAMPLE BELOW).

12 INCH SPACE REQUIRED FOR INSTALLATION OF 3/4" METER WITH TWO (2) 3/4" TAILPIECES.

16 INCH SPACE REQUIRED FOR INSTALLATION OF 1" METER WITH TWO (2) 1" TAILPIECES.

BACKFLOW IS REQUIRED PER PLUMBING REGULATIONS.

ADVANCE NOTICE REQUIRED FOR SCHEDULING INSTALLATION APPOINTMENT OF WATER METER.

WATER DEPARTMENT DOES NOT PROVIDE PLUMBING SERVICES.

WATER METERS INSTALLED BY WATER DEPARTMENT PERSONNEL ONLY.

BALL VALVES INSTALLED BEFORE AND AFTER WATER METER.

ALL UNDERGROUND OR CONCEALED LAWN OR GARDEN WATER SYSTEMS OF ANY TYPE SHALL HAVE A MOISTURE SENSOR SWITCH DEVICE INCORPORATED INTO THEIR CONTROL SYSTEM. THIS MOISTURE SENSOR WILL POSITIVELY PREVENT AUTOMATED WATER SYSTEMS FROM ACTIVATING DURING ANY/ALL RAIN EVENTS. ALL COSTS ASSOCIATED WITH THE PURCHASE, INSTALLATION AND MAINTENANCE OF THESE DEVICES IS THE RESPONSIBILITY OF THE PROPERTY OWNER.

