

NORTH ATTLEBOROUGH WATER DIVISION							
2021 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources							
Sample Collection Date	Water Treatment Plant	Whiting Treatment- with Highway Well	Whiting Treatment- No Highway Well- 10031	McKeon Treatment	Hillman Well	Adamsdale Well (offline since December 2, 2020)	MCL (ng/L)
	EPTDS	Whiting Street	Whiting Street	Mary Kennedy Dr.	Huntsbridge Road	Grandview Drive	
1/27/2021	January	Highway Offline	13.1	13.8	17.4	28.1	20
2/17/2021	February	Highway Offline	11.1	13.7	17.1	22.8	
3/23/2021	March	Highway Offline	15.3	14.1	18.5	24.9	
	Quarter 1 Averages	-	13.2	13.9	17.7	25.3	
4/14/2021	April	Highway Offline	16.2	18.2	18.4	No Longer Sampled	20
5/25/2021	May	19.1	18.6	23.6	18.7		
6/09/2021	June	19.4	23.1	25.6	15.6		
	Quarter 2 Averages	19.3	19.3	22.5	17.6		
7/15/2021	July	25.1	19.3	26.8	16.0		20
8/09/2021	August	16.0	21.4	29.4	13.3		
9/09/2021	September	19.1	20.8	27.7	14.2		
	Quarter 3 Averages	20.1	20.5	28.0	14.5		20
10/14/2021	October	20.6	20.3	24.8	14.9		
11/09/2021	November	17.3	19.2	22.6	15.4		
12/16/2021	December	15.8	15.8	23.5	15.1		
	Quarter 4 Averages	18.2	18.2	23.6	15.1		-

KEY:

EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system) ng/L = nanograms per liter, also equal to parts per trillion (ppt)

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

NOTES:

Yellow highlight = Violation

Red highlight=Offline from system

Violation/compliance with regulation based on locational Quarterly Averages Adamsdale Well is currently an inactive source