

NORTH ATTLEBOROUGH WATER DIVISION								
2023 PFAS6 Monthly Results & Quarterly Averages: Active Drinking Water Sources								
Sample Collection Date	Water Treatment Plant	Whiting Treatment- with Highway Well - 10032	Whiting Treatment- No Highway Well- 10031 (Sampling not required)	McKeon Treatment	Hillman Well	KIOSK - Vending Unit	Adamsdale Well (offline since December 2, 2020)	MCL (ng/L)
	EPTDS	Whiting Street	Whiting Street	Mary Kennedy Dr.	Huntsbridge Road	Whiting Street	Grandview Drive	
1/05/2023	January	16.6	na	25.7	not detected	not detected	No Longer Sampled	20
2/13/2023	February	17.7	na	22.1	15.5	not detected		
3/08/2023	March	15.8	na	20.5	15.8	not detected		
	Quarter 1 Averages	16.7		22.8	10.4			
4/12/2023	April	14.2	na	19.8	16.0	not detected		20
5/08/2023	May	13.8	na	20.2	15.2	not detected		
6/05/2023	June	12.3	na	22.3	14.4	not detected		
	Quarter 2 Averages	13.4	na	20.8	15.2			
7/13/2023	July	11.0	na	21.9	9.8	not detected		20
8/03/2023	August	13.5	na	25.8	13.1	not detected		
9/20/2023	September	16.9	na	27.7	14.5	not detected		
	Quarter 3 Averages	13.8	na	25.1	12.5			
	October						20	
	November							
	December							
	Quarter 4 Averages						-	

KEY:

EPTDS = Entry Point To Distribution System (the location where treated water enters the drinking water system) ng/L = nanograms per liter, also equal to parts per trillion (ppt)

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

NOTES:

Yellow highlight = Violation

Red highlight=Offline from system

Violation/compliance with regulation based on locational Quarterly Averages Adamsdale Well is currently an inactive source