



NOTES:

1. STEEL REINFORCING TO MEET OR EXCEED H20 LOADING
2. MINIMUM DEPTH OF SUMP TO BE 2 FT
3. WHEN A CURB INLET IS INSTALLED, THE OPENING IS TO BE 24"X27"
4. FACE OF PIPE FLUSH OR NOT TO PROJECT MORE THAN 4" FROM FACE OF WALL ALONG CENTERLINE OF PIPE
5. FOR DESCRIPTION, MATERIALS AND CONSTRUCTION METHOD, SEE STANDARD SPECIFICATIONS
6. PLUG ALL LIFTING HOLES IN & OUT WITH HYDRAULIC CEMENT



TOWN OF NORTH ATTLEBOROUGH, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS

Date Last Updated:
03/24/2023

CATCH BASIN DETAIL
N.T.S.

Detail Number:
D-3.2