



NOTES:

1. DO NOT DROP, ROLL, OR LAY UNIT ON IT'S SIDE.
2. ALL PRESSURE PIPE AND FITTINGS TO HAVE A MINIMUM 4' COVER AND ARE TO BE BEDDED IN SAND A MINIMUM OF 6" ALL AROUND.



TOWN OF NORTH ATTLEBOROUGH, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS

Date Last Updated:
03/06/2023

LOW PRESSURE SEWER - BUILDING/PUMP
CONNECTION DETAIL PT.2

Detail Number:
S-7.6

N.T.S.