



NOTE:
FOR DP, W_u , & W_s ,
SEE TABLE A

TABLE A

DIAMETER OF PIPE (DP)	UNSHEETED (W_u)	SHEETED (W_s)
12" AND SMALLER	3' - 4"	4' - 6"
15"	3' - 6"	4' - 8"
18"	3' - 10"	5' - 0"
21"	4' - 2"	5' - 4"
24"	4' - 6"	5' - 8"
27"	4' - 10"	6' - 0"
30"	5' - 6"	6' - 8"
36"	6' - 2"	7' - 4"
42"	6' - 10"	8' - 0"
48"	7' - 6"	8' - 8"

NOTE:
SUITABLE BACKFILL SHALL BE SELECTED FROM EXCAVATED MATERIALS AND IS SUBJECT TO THE APPROVAL OF THE NADPW. FRACTURED ROCK OR HAMMERED/BROKEN LEDGE SHALL NOT BE USED FOR BACKFILL.



TOWN OF NORTH ATTLEBOROUGH, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS

Date Last Updated:
4/24/2023

SEWER TRENCH SECTION DETAIL

N.T.S.

Detail Number:
S-1.1