



**NOTE:**

1. VALVE SPACING TO BE A MINIMUM OF 5'-0" TO ALLOW PROPER SOIL COMPACTION BETWEEN VALVE BONNETS AND BOXES
2. MECHANICAL JOINT WITH RETAINER GLANDS REQUIRED ON ALL FITTINGS AND VALVES.



TOWN OF NORTH ATTLEBOROUGH, MASSACHUSETTS  
DEPARTMENT OF PUBLIC WORKS

Date Last Updated:  
03/02/2023

ANCHOR TEE AND THREE GATES DETAIL

N.T.S.

Detail Number:  
W-5.2