



NOTES:

1. HYDRANT MUST BE BURIED TO PROPER DEPTH (BURY LINE) TO ALLOW SUFFICIENT CLEARANCE TO BOLT/UNBOLT THE UPPER BARREL AND SAFETY FLANGES, IF NEEDED, INSTALL EXTENSION
2. USE BOTH MEGA-LUG RESTRAINT GLANDS AND THRUST BLOCKS. THRUST BLOCKING SHALL HAVE A MINIMUM OF 3 SQUARE FEET AGAINST UNDISTURBED EARTH
3. FIRE HYDRANT PER NORTH ATTLEBOROUGH DPW STANDARDS. REFER TO THE LATEST EDITION OF THE TOWN OF NORTH ATTLEBOROUGH DPW CONSTRUCTION SPECIFICATIONS FOR MANUFACTURER AND MODEL NUMBER.
4. ALL FIRE HYDRANTS SHALL HAVE INSTALLED A 60" HYDRANT MARKER WITH SPRING MOUNTED FIBERGLASS SHAFT AND RED STRIPES OR EQUAL.



TOWN OF NORTH ATTLEBOROUGH, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS

Date Last Updated:
03/02/2023

HYDRANT ASSEMBLY DETAIL

N.T.S.

Detail Number:
W-6.1