



NOTE:

1. PROVIDE SADDLE FOR ALL AC AND PVC MAINS AND ALL 2" OR LARGER STOPS
2. CURB STOPS SHALL "OPEN LEFT"
3. 2.5" CURB BOX SHALL BE BUFFALO STYLE WITH ARCH BASE AND 5/8" DIAMETER EXTENSION ROD, 36" LONG OR AS REQUIRED TO EXTEND TO WITHIN 18" OF THE TOP OF THE BOX
4. 3" WIDE BLUE TRACER TAPE MARKED "CAUTION BURIED WATER LINE BELOW" MUST BE PLACED APPROXIMATELY 12" BELOW FINISHED GRADE IN THE WATER SERVICE TRENCH TO EACH RESIDENCE AND TIED TO THE CURB BOX
5. BRASS FITTINGS SHALL BE AS MANUFACTURED BY RED HEAD OR MUELLER CO.
6. 1" PLASTIC PIPE W/ TRACER WIRE MAY BE USED ON HOME OWNER'S SIDE OF CURB STOP.



TOWN OF NORTH ATTLEBOROUGH, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS

Date Last Updated:
01/09/2024

TYPICAL WATER SVC CONNECTION DETAIL (1")

N.T.S.

Detail Number:
W-1.1